

2023 Annual Drinking Water Quality Report

(Consumer Confidence Report)

CITY OF CELESTE

Phone Number 903-568-4512

Annual Water Quality Report for the period of January 1 to December 31, 2023.

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

For more information regarding this report contact:

Cherie Hubbard
(903) 568-4512

Este reporte incluye informacion importante sobre el agua para tomar. Para asistencia en espanol, favor de llamar al telefono (903) 815-2823.

City of Celeste provides ground water from Woodbine Aquifer, Groundwater located in Celeste, Texas.

Information about Source Water

TCEQ completed an assessment of your source water, and results indicated that our sources have a low susceptibility to contaminants. The sampling requirements for your water system is based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system contact 903-364-1016.

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL:

<http://www.tceq.texas.gov/gis/swaview>

Further details about sources and source water assessments are available in Drinking Water Watch at the following URL:

<http://dww2.tceq.texas.gov/DWW/>

Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pickup substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; person who have undergone organ transplant those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can

minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water Quality Test Results	
Definitions	The following tables contain scientific terms and measures, some of which may require explanation.
Action Level:	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Action Level Goal (ALG):	The level of a contaminant in drinking water below which there is no known or expected risk to health, ALGs allow for a margin of safety.
Avg	Regulatory compliance with some MCLs are based on running annual average of monthly samples
Maximum Contaminant Level or MCL	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal or MCLG	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum residual disinfectant level goal or MRDL	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum residual disinfectant level goal or MRDLG	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MFL	Million fibers per liter (a measure of asbestos)
mrem	Millirems per year (a measure of radiation absorbed by the body)
na	Not applicable
NTU	Nephelometric turbidity units (a measure of turbidity)
pCi/L	Picocuries per liter (a measure of radioactivity)
ppb	Micrograms per liter or parts per billion – or one ounce in 7,350,000 gallons of water
ppm	Milligrams per liter or parts per million – or one ounce in 7,350 gallons of water
ppq	Parts per quadrillion, or picograms per liter (pg/L)
ppt	Parts per trillion, or nanograms per liter (ng/L)

Lead and Copper

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90 th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2023	1.3	1.3	.269	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	2023	0	15	2.4	0	ppb	N	Corrosion of household plumbing systems; erosion of natural deposits.

2023 Water Quality Test Results

Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)*	2023	6	5.5-5.5	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
*The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year.								
Total Trihalomethanes (TTHM)	2023	22	21.5-21.5	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
*The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year.								

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	07/13/2021	0.006	0.006-0.006	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Chromium	07/13/2021	6.8	6.8-6.8	100	100	ppb	N	Discharge from steel and pulp mills; Erosion of natural deposits.
Fluoride	07/13/2021	1.45	1.45-1.45	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum
Nitrate (measured as Nitrogen)	2023	0.0546	0.0546-0.0546	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Nitrite (measured as Nitrogen)	05/16/2019	0.0255	0.0255-0.0255	1	1	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	07/13/2021	1.5	1.5-1.5	0	5	pCi/L	N	Erosion of natural deposits.

Disinfectant Residual Table

Disinfectant	Year	Average Level	Minimum Level	Maximum Level	MRDL	MRDLG	Unit of Measure	Violation (Y/N)	Likely Source of Contamination
Chlorine (Free)	2023	1.79	.50	3.08	4	4	mg/L	N	Water additive used to control microbes.

Visit www.ntmwd.com for helpful tips on conserving water.